Henrico County Construction Dewatering Turbidity Log											
Project Name:			**VAR10 Number**								
Turbidity Meter Daily Calibration:	**Meter Model:**	**Calibration Standard (NTU or FTU):**	**Calibration Reading (NTU or FTU):** **Pass** **Fail**								
Select One:	**Benchmark 1:** Dewatering Sample Turbidity < Turbidity of Upstream Sample + 50 NTU/FTU		**Benchmark 2:** Dewatering Sample Turbidity ≤ 150 NTU/FTU						**Benchmark 3:** Dewatering Sample Turbidity Weekly Average ≤ 50 NTU/FTU		
Sample Date & Tme	**Sample Location**	**Turbidity Result (NTU/FTU)** Upstream / Downstream	**Visual Monitoring.** Check below if present.						**Corrective Action(s) / Comments**	**Initials**	
			Foam	**Oil Sheen**	**Floatables**	**Solids**	**Odor**	**Color**			
Turbidity Monitoring Certification: "I certify under penalty of law that I have read and understand this document and that this document and all attachments were prepared in accordance with a system designed to assure that qualified personnel properly gathered and evaluated the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."											
Signature of Duly Authorized Representative:			**Date:**								