




SECTION ELEVATION AT GUTTER LINE

NOTES:

1. MODIFICATIONS TO THIS DETAIL MAY BE REQUIRED FOR SIDEWALKS AND MOBILITY IMPAIRMENT REQUIREMENTS.
2. #21-B STONE SHALL BE COMACTED IN ACCORDANCE WITH DPW DESIGN MANUAL SECTION 2.48.
3. CONCRETE SHALL BE CLASS A-3.

CONCRETE APRONS ARE REQUIRED IF:

1. THERE IS A CURB INLET WITHIN 25' OF THE ENTRANCE.
2. THE LOT ADJACENT TO THE DRIVEWAY IS LOWER THAN THE CURB.
3. IN A SAG OF A VERTICAL CURVE



STANDARD ENTRANCE APRON (FOR RESIDENTIAL USE ONLY)

County of Henrico
Department of Public Works

SEPTEMBER 1, 2021

C-9.DWG